

10th May 2005

Mr Jim Santaguida
Team Leader - Station Sustainment
Investment Planning
Hydro One Networks Inc.
15th Floor, North Tower
483 Bay Street
Toronto M5G 2P5

Independent Electricity
System Operator
Station A, Box 4474
Toronto, Ontario M5W 4E5
t 905 855 6100
www.ieso.ca

Dear: Mr Santaguida,

***Bramalea TS: Replacement of the 44kV Breaker SC4Q
Notification of Approval to Connect
CAA ID Number: 2005-EX231***

Thank you for participating in the IESO's Connection Assessment and Approval process.

The 44kV breaker associated with the SC4 shunt capacitor bank at Bramalea TS failed recently and is to be replaced with a new unit. The specification for the replacement unit is attached, and since this is essentially the same as that for the failed unit, this is considered to be a like-for-like installation and will therefore have no adverse impact on the IESO-controlled grid.

The IESO is therefore pleased to grant **conditional approval** of your proposal to replace the breaker that failed with a new unit.

Final approval will be granted upon successful completion of the IESO Facility Registration process.

A copy of this Notification of Approval will also be provided to the Ontario Energy Board (OEB) and a further copy will be posted on the IESO web site: www.ieso.ca

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IESO Records