

October 31, 2002

File: 2002-EX061

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Chesterville TS – Replace 115kV Interrupter A1-A2
Notification of Approval of Connection Proposal***

CAA ID Number: 2002-EX061

The IMO has completed a review of your application to replace the existing 115kV 1200A interrupter A1-A2 at Chesterville TS with a new Interrupter of similar rating. Based on the information provided, we have concluded that the proposal is a like-for-like replacement of existing facilities and a formal Connection Assessment study will therefore not be necessary.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.