

October 31, 2002

File: 2002-EX062

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Dobbin TS – Replace 230kV Line Disconnect Switch X1P
Notification of Approval of Connection Proposal***

CAA ID Number: 2002-EX062

The IMO has completed a review of your application to replace the existing 230kV 1,200A disconnect switch associated with the 230kV Dobbin TS to Chenux GS transmission line X1P at Dobbin TS with a new switch of similar rating. Based on the information provided, we have concluded that the proposal is a like-for-like replacement of existing facilities and a formal Connection Assessment study will therefore not to be necessary.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.