



SIA Report

*Near-Term Measures for the Return-to-Service of two units at Bruce 'A' NGS:
Install Seven 230kV Capacitor Banks
in South-Western Ontario*

1.0

CAA ID No. 2007-295

Transmission Assessments & Performance Department

FINAL DRAFT Version

Date: 12th February 2008

Revised: 12th February 2009

HYDRO ONE NETWORKS Inc.: Middleport TS, Nanticoke TS & Buchanan TS

Install Seven 230kV Shunt Capacitor Banks

1. Summary

In their letter to Hydro One dated 3rd December 2007, the Ontario Power Authority instructed Hydro One to proceed with the installation of seven 230kV shunt capacitor banks in south-western Ontario in preparation for the return to service of the remaining two generating units at Bruce 'A' NGS in May 2009. The new shunt capacitor banks are to be installed at the following locations:

- Middleport TS Four shunt capacitor banks: each rated at 250MVAR at 250kV
- Nanticoke TS Two shunt capacitor banks: each rated at 250MVAR at 250kV
- Buchanan TS One shunt capacitor bank: rated at 200MVAR at 250kV

Unit G2 at the Bruce 'A' NGS is scheduled to return to service in Q2-2009, with unit G1 scheduled to follow in Q4-2009. However, prior to the return to service of unit G1, one of the existing units is scheduled to be removed from service for long-term maintenance. During the interim period until the new 500kV line between the Bruce Complex and Milton TS becomes available there are therefore only expected to be a maximum of seven units in-service at the Bruce Complex, together with all of the committed wind-turbine projects.

The seven capacitor banks are therefore intended to supply the reactive power requirements in the area so that an acceptable pre-contingency voltage profile can be maintained with all transmission elements in-service when seven Bruce units, together with all 675MW of the committed wind-turbine facilities, are in-service. It has also been assumed that there will be no restrictions on the transfers across the Negative-BLIP Interface and that transfers of up to 1500MW could be accommodated across this Interface.

This requirement for an additional 1700MVAR of reactive capacity also assumes that none of the existing generating units at Nanticoke GS will be available to provide pre-contingency reactive support.

This Assessment has concluded that the installation of the seven capacitor banks would increase the pre-contingency voltage stability limit for transfers across the FABC (Flow Away from the Bruce Complex) to approximately 6675MW. This value corresponds to the situation with all of the committed wind-turbine projects in-service and with a transfer of 1500MW across the Negative-BLIP Interface.

Since the required transfer limit with seven units operating at the Bruce Complex would be 6208MW, the increased limit achieved by installing the seven new capacitor banks would therefore be more than adequate to accommodate the output from the seven generating units.

This Assessment has also shown that the voltage changes that would be experienced when individually switching the new capacitor banks would be approximately 2%, which would be well within the maximum of 4% allowed under the Market Rules.

Since it has been determined that there would be no adverse effect on the IESO-controlled grid from the installation of the seven shunt capacitor banks at Middleport TS, Nanticoke TS & Buchanan TS, it is therefore recommended that a Notification of Conditional Approval of the Connection Proposal be issued for these facilities.

Scheduled In-service Dates

The seven shunt capacitor banks are scheduled to come into service in stages during the period May to October of 2009.

2. Proposed New Facilities

Following the explosive failure of the 400MVAR SC22 shunt capacitor bank at Richview TS on 30th January 2007, Hydro One has identified additional measures to limit the possibility that any of these new capacitor banks should experience a similar failure. These measures include:

- the installation of capacitive voltage transformers to limit the rate of rise in the recovery voltage (RRRV) that was recorded across the breakers of the Richview capacitor bank when they attempted to interrupt the fault current.
- the installation of breakers with a fault interrupting capability of 80kA.
- the installation of insulators on the individual capacitor cans that have a greater creepage profile to reduce the possibility of flashovers under moderate levels of contamination, and
- the inclusion of breaker-failure protection to initiate automatic operation of the breakers in the next protection zone in the event that the breakers associated with the shunt capacitor bank should fail to operate.

The following Figure shows the proposed arrangement that is to be used for each of the new capacitor bank installations:




Figure 1: Typical Arrangement for the new Shunt Capacitor Bank Installations

Location of the new Capacitor Banks at Middleport TS, Nanticoke TS & Buchanan TS

The locations within the 230kV switchyards at Middleport TS, Nanticoke TS & Buchanan TS where the new shunt capacitor banks are to be connected are shown in Diagrams 1, 2 & 3, respectively,

Middleport TS

At Middleport TS, which has existing bus-section breakers, each new capacitor bank is to be connected to one of the four main busbar sections. However, to limit the size of the series reactors that are to be installed on each capacitor bank to 3.3mH, it has been agreed that the 230kV busbar will be operated split whenever more than two capacitors banks are required to be in-service. Without this restriction, the rating of the series reactors would increase to 6.6mH.

Nanticoke TS

Nanticoke TS also has existing bus-section breakers, resulting in there being four main busbar sections. To each of these busbar sections is connected one of the existing Nanticoke generating units. In addition, busbar sections K2 & P1 each has a Station Service transformer connected to it.

The new capacitor banks are to be connected to the two remaining busbar sections that do not have a Station Service transformer connected to it: the K1-bus & P2-bus.

On the assumption that the 230kV busbar at Nanticoke TS will continue to be operated closed, and since only two capacitor banks are to be installed at that station, a rating of 3.3mH for the series reactors to be installed on each bank would therefore be sufficient to limit the out-rush currents to an acceptable level.

Buchanan TS

Since Buchanan TS has no bus-section breakers, there are therefore only two main busbars at this station. A shunt capacitor bank is already connected to each of these busbars, so in order to provide a connection point for the new capacitor bank, a new 230kV breaker is to be installed in one of the existing 230kV diameters.

With a total of three shunt capacitor banks installed at Buchanan TS, the series reactors will need to be rated at 5.0mH to limit the out-rush currents to an acceptable level.

Since the series reactors on the two existing capacitor banks are only rated at 1.0mH, these are to be replaced with 5.0mH units.

Operational Requirement

Energisation of the new capacitor banks must be possible without implementing any special operating procedures.

Scheduled In-Service Date

The new shunt capacitor banks are scheduled to be placed in-service, in stages, beginning in May 2009 and finishing in October 2009.

3. Equipment Specifications

Details of the new facilities that are to be installed at each transformer station have been summarised below:

3.i Shunt Capacitor Banks

Shunt Capacitor Banks	
Rated Capacitance	6 banks 250MVAR (Max.) to 240MVAR (Min.) at 250kV ± 1kV
	1 bank 200MVAR (Max.) to 190MVAR (Min.) at 250kV ± 1kV
Rated Maximum Voltage	255kV _{rms}
Maximum system voltage unbalance	2%
Symmetrical Short Circuit Level	63kA _{rms} (min)
Configuration	Double-wye ungrounded
Fusing	Fuseless
Insulation Level	900kV _{peak} BIL (min)
Discharge Devices	None, other than the standard 5-minute discharge resistor provided with each capacitor bank
Contamination Withstand	The largest available creep bushings (assumed to be ~ 43mm/kV) are to be installed on the individual capacitor units comprising the bank

3.ii Series Reactors

Each capacitor bank is to be equipped with three, single-phase transient current limiting reactors to maintain the magnitude and frequency of the out-rush current to an acceptable level.

The existing 1.0mH reactors installed on the SC21 & SC22 capacitor banks at Buchanan TS are to be replaced with 5.0mH units to accommodate the installation of the third shunt capacitor bank at that location.

Current Limiting Series Reactors			
Number required: A total of 27	Middleport TS	12 units	Three for each capacitor bank (one per phase)
	Nanticoke TS	6 units	
	Buchanan TS	9 units	
Type	Air-cored		
Rated System Voltage (line-to-line)	240kV _{rms}		
Rated Maximum Voltage	255kV _{rms}		
Emergency Operating Voltage	300kV _{rms} for 5 minutes		
Inductance at Rated Frequency of 60 Hz	Middleport TS	3.3mH per phase	
	Nanticoke TS	3.3mH per phase	
	Buchanan TS	5.0mH per phase	
Continuous Current (rms)	800A _{rms}		
Symmetrical Fault Current	63kA _{rms} for 0.5 seconds		
Asymmetrical Fault Current	108kA _{peak}		
Insulation Level:	900kV _{peak} BIL		

3.iii 230kV Circuit Breakers

The new capacitor bank is to be equipped with both a Primary & a Secondary (back-up) circuit breaker, connected in series.

Both the Primary & Secondary circuit breaker is to be equipped with 362kV interrupters to allow switching of the capacitor banks at voltages up to 255kV in order to allow a maximum continuous voltage of 250kV on the 230kV system to be respected.

Independent Pole Operated (IPO) breakers are to be installed for both the Primary & Secondary breaker at Nanticoke TS & Middleport TS, although only the Primary breakers are to be equipped with Synchronising Control Units. At Buchanan TS, a ganged-pole breaker is to be installed as the Secondary breaker.

230kV Primary Breakers

230kV Circuit Breakers: Primary units	
Number required: A total of 7	Middleport TS 4 breakers
	Nanticoke TS 2 breakers
	Buchanan TS 1 breaker
Breaker Type	SF ₆ - Independent pole operated (IPO) equipped with control units for synchronized closing. Outdoor dead tank with CTs for protection & metering.
Rated Maximum Voltage	255kV _{rms} (min) [362kV Interrupters are to be installed.]
Rated Interrupting Current	Middleport & Nanticoke TSs 80kA _{rms} symmetrical
	Buchanan TS 63kA _{rms} symmetrical
Rated Continuous Current	2000A _{rms}
Inter-pole Closing Time Spread Limit	2.0ms (max)
Closing and Latching Capability	170kV _{peak}
Shunt Capacitor In-rush Current Capability	20kA _{peak} (magnitude) 4250Hz (frequency)
Tested Transient Recovery Voltage (TRV) across pole	620kV _{peak} (3 per unit)
Insulation Level	900kV _{peak} BIL (min)
Insulation Level across open CB	1050kV _{peak} BIL (min)
Rated Interrupting Time	3 cycles (max)
Interrupter	Restrike-free (up to 620kV _{peak} TRV) and Pre-strike free when switching a 250MVA _r ungrounded-ye capacitor bank, rated at 250kV.

Secondary (Back-up) Breaker

230kV Circuit Breakers: Secondary units	
Number required: A total of 7	Middleport TS 4 breakers
	Nanticoke TS 2 breakers
	Buchanan TS 1 breaker
Breaker Type	At Nanticoke & Middleport TSs: SF ₆ : Independent pole operated (IPO) without SCUs
	At Buchanan TS: SF ₆ : Ganged-pole
	General (all three locations): Outdoor dead tank with CTs for protection & metering.
Rated Maximum Voltage	255kV _{rms} (min) [362kV Interrupters are to be installed.]
Rated Interrupting Current	Middleport & Nanticoke TSs 80kA _{rms} symmetrical
	Buchanan TS 63kA _{rms} symmetrical
Rated Continuous Current	2000A _{rms}
Closing and Latching Capability	170kV _{peak}
Tested Transient Recovery Voltage (TRV) across pole	620kV _{peak} (3 per unit)
Insulation Level	900kV _{peak} BIL (min)
Insulation Level across open CB	1050kV _{peak} BIL (min)
Rated Interrupting Time	3 cycles (max)
Interrupter	Restrike-free (up to 620kV _{peak} TRV) and Pre-strike free when switching a 250MVAR ungrounded-wye capacitor bank, rated at 250kV.

Station Breaker

230kV Circuit Breaker: For Installation in the existing diameter at Buchanan TS	
Number required	Buchanan TS 1 breaker
Breaker Type	SF ₆ : General Purpose
Rated Maximum Voltage	250kV _{rms} (min)
Rated Interrupting Current	63kA _{rms} symmetrical
Rated Continuous Current	3000A _{rms}
Closing and Latching Capability	170kV _{peak}
Tested Transient Recovery Voltage (TRV) across pole	As per ANSI Standard C37.11 - 1979 (Re-affirmed 1988)
Insulation Level	900kV _{peak} BIL (min)
Insulation Level across open CB	1050kV _{peak} BIL (min)
Rated Interrupting Time	3 cycles (max)
Other	Suitable for energising up to 100km of 230kV line

3.iv 230kV Disconnect Switches

230kV Disconnect Switches		
Number required: A total of 7	Middleport TS	4 disconnect switches
	Nanticoke TS	2 disconnect switches
	Buchanan TS	1 disconnect switches
Type	Motor operated, 3-phase unit	
Continuous Current (min)	1200A _{rms}	
Operating Voltage	230kV _{rms} (nominal), 255kV (max. continuous), 300kV _{rms} (emergency for 5 minutes)	
Insulation Level (phase-to-ground & phase-to-phase) (min)	900kV _{peak} BIL	
Short-circuit Withstand Capability (min)	63kA _{rms} symmetrical	

3.v Ground Switches

A total of seven sets of 3-phase ground switches are to be installed: one set on each capacitor bank installation, located between the capacitor bank and the breaker closest to it. These switches are to have a symmetrical fault rating of at least 63 kA

A further seven, single-phase ground switches are also to be installed on each capacitor bank installation, connected to the neutral point of each new capacitor bank for use during maintenance.

3.vi Surge Arresters

In the event that one of the poles of the IPO breaker should not open, or as a result of delayed opening of a pole, a transient recovery voltage of up to $4.37 E_{max}$ phase-to-ground could occur. Surge arresters are therefore to be installed to limit the transient recovery voltage to below $3 E_{max}$ phase-to-ground (612kV_{peak}).

The surge arrestors are to be located between the series reactors and the capacitor banks.

230kV Surge Arresters			
Number required: A total of 21	Middleport TS	12 units	Three for each capacitor bank (one per phase)
	Nanticoke TS	6 units	
	Buchanan TS	3 units	
Type	Metal Oxide Gapless – Station Class		
Maximum Continuous Operating Voltage (MCOV)	150kV _{rms} (minimum)		
Front-of-Wave Impulse Protective Level	Maximum Equivalent Front-of-Wave not more than 720kV _{crest}		
Maximum discharge voltage for 8x20μs 10kA impulse current	Not more than 460kV _{crest}		
Maximum Switching Surge Protection Level	Not more than 380kV _{crest} at 1kA		
Temporary Over-voltage Capability	Capable of withstanding a power frequency over-voltage of not less than 200kV Phase-Ground (rms) for a duration of not less than 1 second after the rated energy absorption.		
Maximum energy dissipation per arrester	Not less than 1500kJ/phase (i.e. single impulse energy capability).		
Pressure relief capability	As recommended by ANSI/IEEE C62.11-1993 Standard: not less than 65kA _{rms}		

3.vii Surge Capacitors

Surge capacitors, consisting of a three-phase set of capacitive voltage transformers, are to be installed on each capacitor bank between the primary (IPO) breaker and the series reactor. Their purpose is to ensure that the rate of rise of the recovery voltage (RRRV) for a 3-phase fault on the capacitor bank remains within the fault interrupting capability of the breakers.

The 50nF surge capacitors that are presently installed on the SC21 & SC22 capacitor banks at Buchanan TS are to be replaced with units rated at 70nF.

230kV Surge Capacitors (CVTs)			
Number required: A total of 27	Middleport TS	12 units	Three for each capacitor bank (one per phase)
	Nanticoke TS	6 units	
	Buchanan TS	9 units	
Rated Maximum Voltage	250kV _{rms} (min)		
Rated Capacitance	Middleport TS	50nF	Four 3-phase sets
	Nanticoke TS	50nF	Two 3-phase sets
	Buchanan TS	70nF	Three 3-phase sets
Insulation Level (phase-to-ground) (min)	1050kV _{peak} BIL		

3.viii Protection, Control, Communications & Monitoring

In addition to the standard relay protection, control, communications & monitoring facilities, breaker failure protection is to be installed to clear the next protection zone should the capacitor breakers fail to clear a fault involving the capacitor bank installation.

Since all three stations where the new capacitor banks are to be installed have been designated as NPCC-impactive stations, all of the new protection facilities have been designed to comply with NPCC Criteria Document A5.

4.0 Assessment

The results from a load flow study for the expected peak load condition during the summer-2009 have been summarised in Diagram 4. In this study, a total of seven generating units at the Bruce Complex, together with the 675MW of committed wind-turbine projects have been assumed to be in-service. A peak transfer of approximately 1500MW across the Negative-BLIP Interface has also been assumed.

The corresponding primary demand for the summer-2009 that was used in this study was 28400MW.

All available shunt capacitor banks, including the seven units that are the subject of this Report, were also assumed to be in-service in this study.

Even with these capacitor banks, together with all transmission elements in-service, the voltages at Guelph-Cedar TS, Grand Bend TS & Brant TS were found to be below the minimum acceptable value of 113kV, as stipulated in the Market Rules. Additional shunt capacitors, with the nominal ratings shown below, were therefore added to these 115kV busbars to raise their voltages above the 113kV minimum:

- Guelph-Cedar TS 40MVar
- Grand Bend TS 20MVar &
- Brant TS 30MVar.

While the resulting voltage profile that is shown in Diagram 1 would be acceptable, it is worth noting that the voltage at Milton TS (523.9kV) would be close to the minimum value of 522kV (for a primary demand above 24500MW) that is stipulated in the current version of the operating instructions for southern Ontario.

Power-Voltage Analysis

Diagrams 5 & 6 show the results from the PV-Analysis that was performed on the reference case shown in Diagram 4. For this analysis, the output from the Bruce Complex was gradually increased to stress the transmission system between the Bruce Complex and the GTA. To compensate for the increased output from the Bruce Complex, corresponding decreases were made in the output from Darlington GS.

Diagram 6, in which the reactive outputs remaining available from the principle generating facilities in the area have been summarised, shows the reactive outputs from the Bruce & Pickering generating units reaching their maximum limits for FABC transfers of approximately 7300MW & 7400MW, respectively. Once the generating units at the Bruce Complex and at Pickering GS were unable to provide further support, termination of the study occurred at an FABC Transfer of 7417MW.

With the knee points of the PV-curves occurring at an FABC Transfer of 7417MW, the pre-contingency voltage stability limit, which requires a margin of 10% to be maintained from the knee-point of the PV-curves, would therefore correspond to a maximum FABC Transfer of 6675MW, as shown in Diagram 5.

Diagram 5 also shows that in order to provide the required 10% margin on the maximum FABC Transfer of 5587MW that is expected to occur once seven Bruce units are in-service, as was shown in Diagram 4, the voltage stability limit would need to be at least 6208MW. The actual transfer limit of 6675MW would therefore be well in excess of this minimum required value of 6208MW.

However, since an eighth unit at the Bruce Complex would add approximately 750MW to the FABC Transfer, the required voltage stability limit would therefore need to increase to approximately 7040MW to accommodate all eight Bruce units. Since the voltage stability limit with the seven new capacitor banks in-service has been shown to be only 6675MW, it would therefore not be sufficient to meet the pre-contingency voltage stability criterion for the condition with all eight units at the Bruce Complex in operation.

Should it be necessary to operate all eight units at the Bruce Complex with no new transmission facilities in place, then additional dynamic reactive support would need to be installed since it is not expected that any additional shunt capacitor banks could be placed in-service pre-contingency without exceeding the voltage rating of the existing equipment on the system.

Load Flow Analysis

Diagram 7 shows the results from the load flow study performed on the limiting case from the PV-analysis. This corresponds to an FABC Transfer of 7417MW, which would be approximately 32% above the reference FABC Transfer shown in Diagram 4, of 5586MW.

This shows the reduced voltages at the Bruce Complex and within the GTA, particularly at Burlington TS and Milton TS, in response to absence of any further voltage support from the generating units at the Bruce Complex and at Pickering NGS.

Voltage Change on Switching the Individual Capacitor Banks

The results from the studies that examined the effect of individually switching one of the new capacitor banks out-of-service at each location are summarised below.

In these studies the loads were modelled as 'voltage dependent' (i.e. $P \propto V^{1.5}$ & $Q \propto V^2$), in accordance with the Ontario Resource & Transmission Assessment Criteria for switching reactive devices.

The results correspond to the situation immediately following the switching of each capacitor bank, before the transformer tap-changers have had an opportunity to respond.

<i>Location of Capacitor Bank being Switched</i>		<i>Nanticoke</i>	<i>Middleport M585M</i>	<i>Middleport V586M</i>	<i>Detweiler</i>	<i>Buchanan</i>
Size of Capacitor Bank (Q)		250MVA _r	250MVA _r	250MVA _r	250MVA _r	200MVA _r
Fault Level at 230kV busbar		12431MVA	15411MVA	17129MVA	8910MVA	12392MVA
ΔQ/Fault Level		2.01%	1.62%	1.46%	2.81%	1.61%
		<i>Nanticoke</i>	<i>Middleport M585M</i>	<i>Middleport V586M</i>	<i>Detweiler</i>	<i>Buchanan</i>
<i>Monitored Busbars</i>	<i>Pre-switching</i>	<i>Post capacitor bank switching</i>				
Nanticoke 230kV	245.06kV	240.48kV 1.87%	243.21kV 0.75%	243.26kV 0.73%	244.05kV 0.41%	244.17kV 0.36%
Middleport M585M 230kV	243.98kV	242.13kV 0.76%	240.65kV 1.36%	242.59kV 0.57%	242.76kV 0.50%	242.97kV 0.41%
Middleport V586M 230kV	243.85kV	242.01kV 0.75%	242.43kV 0.58%	240.63kV 1.32%	242.63kV 0.50%	242.95kV 0.37%
Detweiler 230kV	242.04kV	240.97kV 0.44%	240.75kV 0.53%	240.79kV 0.52%	236.40kV 2.33%	240.50kV 0.64%
Buchanan 230kV	239.91kV	239.19kV 0.30%	239.05kV 0.36%	239.21kV 0.29%	238.59kV 0.55%	236.16kV 1.56%
Orangeville 230kV	245.70kV	245.08kV 0.25%	245.03kV 0.27%	245.05kV 0.26%	243.43kV 0.92%	244.98kV 0.29%
Longwood 230kV	244.18kV	243.60kV 0.24%	243.69kV 0.20%	243.77kV 0.17%	243.59kV 0.24%	242.58kV 0.66%
Nanticoke 500kV	547.04kV	542.17kV 0.89%	544.08kV 0.54%	544.13kV 0.53%	545.24kV 0.33%	545.24kV 0.33%
Middleport M585M 500kV	543.55kV	539.74kV 0.70%	540.40kV 0.58%	541.03kV 0.46%	541.83kV 0.32%	541.95kV 0.29%
Middleport V586M 500kV	544.54kV	540.60kV 0.72%	541.95kV 0.48%	541.35kV 0.59%	542.79kV 0.32%	542.95kV 0.29%
Milton 500kV	530.56kV	528.61kV 0.37%	528.86kV 0.32%	528.95kV 0.30%	529.41kV 0.22%	529.59kV 0.18%
Longwood 500kV	546.59kV	544.99kV 0.29%	545.39kV 0.22%	545.52kV 0.20%	545.35kV 0.23%	543.88kV 0.50%
Detweiler 118kV	125.16kV	124.57kV 0.47%	124.47kV 0.55%	124.44kV 0.57%	122.41kV 2.20%	124.38kV 0.62%

Included in the table is the voltage decline that would be expected to occur based on the size of the capacitor bank being switched and the fault level at that particular busbar. In all cases, this approach is shown to yield a slightly higher voltage change, primarily because the rating assumed for the capacitor bank being switched corresponds to the maximum continuous system voltage of 250kV.

In all instances the voltage declines recorded were less than the 4% limit specified in Reference 1 of Appendix 4.4 of the Market Rules for the maximum abrupt voltage change that is permitted for capacitor switching operations.

5.0 Conclusions

The study results have shown that the installation of the seven shunt capacitor banks at Middleport TS, Nanticoke TS & Buchanan TS would increase the pre-contingency voltage stability limit for Transfers across the FABC Interface to approximately 6675MW for the condition with all the committed wind-turbine projects in-service and with a transfer of 1500MW across the Negative BLIP Interface.

This increased limit would be sufficient to accommodate a total of seven generating units at the Bruce Complex, when all transmission facilities are in-service. Additional dynamic reactive support would need to be installed to accommodate all eight units at the Bruce Complex, again with all transmission elements in-service, should the proposed Bruce-to-Milton 500kV double-circuit line be delayed.

Additional reactive facilities, which are not covered by this Assessment, will also be required to address the system requirements following system contingencies.

The study results have also shown that the individual switching of any of the new capacitor banks would result in a maximum voltage change of approximately 2%, which would be well within the maximum of 4% allowed under the Market Rules.

6.0 Customer Impact Assessment

Hydro One has notified the IESO that a formal Customer Impact Assessment will not be required for the new capacitor banks to be installed under this Project.

7.0 Notification of Approval

Since it has been determined that there would be no adverse effect on the IESO-controlled grid from the installation of the seven shunt capacitor banks at Middleport TS, Nanticoke TS & Buchanan TS, it is therefore recommended that a Notification of Conditional Approval of the Connection Proposal be issued for these facilities.






DIAGRAM 1

9th February 2008




NANTICOKE TS: 230kV Switchyard



BUCHANAN TS: 230kV Switchyard

DIAGRAM 3

9th February 2008



KEY
 Transmission Facilities
 500kV Facilities
 230kV Facilities
 115kV Facilities
 10MW C23Z & C24Z
 Port Alma Wind Project

GENERATION
 Lennox 1450MW
 Darlington 2700MW
 Pickering 2708MW
 Portlands GS 560MW
 Sithe-Goreway GS 615MW
 Halton Hills GS 0MW
 Brighton Beach 526.0MW
 Windsor (115kV) 192.4MW
 TransAlta 370.8MW
 Calpine, St. Clair
 Lambert & Imp Oil 1970MW

Load Flow Results:



Primary Demand: 28400MW

With Seven Bruce Units & 675MW of Wind-turbine Generation in Bruce Area
 With a 1500MW Negative-BLIP Transfer
 With No Nanticoke Units In-Service
 With No SVCs In-Service


MICHIGAN IMPORTS:	1497.7MW
NEW YORK IMPORTS at Niagara:	1000.4MW
Losses on the Ontario System:	1005.3MW

Reference Case used for the Power-Voltage Analysis

DIAGRAM 4
 8th February 2008



Voltage Response at selected 500kV & 230kV busbars to increases in the FABC Transfer



Reactive output remaining available at the principle generating facilities in response to increases in the FABC Transfer

DIAGRAM 6
6th February 2008

