

November 4, 2002

File: 2002 – EX064

Mr. Mel Yates  
Manager, T&D Stations Sustainment Programs  
Investment Planning Division  
Hydro One Networks Inc.  
483 Bay Street  
15<sup>th</sup> Floor - North Tower  
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Notification of Approval of Connection Proposal  
Hamilton Kenilworth TS – Replace Four 138kV 1,200A Interrupts and Four Grounding Switches  
Associated with Circuits H5K, H6K, K1G, and K2G***

***CAA ID Number: 2002 – EX064***

The IMO has completed a review of your application to replace the existing 138kV 1,200A interrupts and 138kV grounding switches associated with the 115kV Kenilworth TS to Beach TS circuits H5K/H6K and the 115kV Kenilworth TS to Gage TS circuits K1G/K2G with new units of similar ratings at Hamilton Kenilworth TS. Based on the information provided, we have concluded that the proposal is a like-for-like replacement of existing facilities and would have no adverse impact on the IMO-controlled grid.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons  
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.