

November 4, 2002

File: 2002 – EX078

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Notification of Approval of Connection Proposal
Ottawa Riverdale TS: Replace 115kV 1,200A Line Disconnect Switch and 115kV Grounding
Switch Associated with 115kV Circuit A3RM***

CAA ID Number: 2002 – EX078

The IMO has completed a review of your application to replace the existing 115kV 1,200A line disconnect switch and the 115kV grounding switch associated with the Hawthorne TS x Merivale TS x Riverdale TS transmission circuit A3RM with new units of similar ratings at Ottawa Riverdale TS. Based on the information provided, we have concluded that the proposal is a like-for-like replacement of existing facilities and would have no adverse impact on the IMO-controlled grid.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.