



13th July, 2001

Mr. Raj Ghai

Senior Planning Engineer
Investment Planning Division
Hydro One
483 Bay Street
Toronto, Ontario, M5G 2P5

Dear Mr. Ghai:

***Replacement of Generator Step-up Transformer at Calm Lake GS
Notification of Approval of Connection Proposal
CAA ID Number: 2001-EX002***

Thank you for the detailed information that you provided on the Abitibi Consolidated Inc. proposal to replace the existing 6.6/115 kV step-up transformer at Calm Lake GS.

We have reviewed the data and concluded that this project can be classified as a “like-for-like” replacement because:

- the new transformer has the same characteristics, capability and winding configuration as the old transformer,
- the proposal meets the requirements of the Transmission System Code for connection of generators to the reliability of the IMO controlled grid,
- the proposed change in the location of the transformer substation does not have a material impact on the IMO controlled grid.

Based on the above factors we have determined that a formal Connection Assessment Study is not warranted.

The IMO is therefore pleased to grant approval to complete the construction process for the replacement of this transformer. A copy of this Notification of Approval will also be provided to the Ontario Energy Board (OEB).

To commence the construction process, please follow the necessary procedures and obtain the required approvals, licences and permits as may be required by the OEB, the Transmitter and other regulatory authorities.

Please note that the new facilities will also have to meet the requirements of the IMO’s Facility Registration process before being placed in service.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons

Manager - Long Term Forecasts & Assessments

Telephone: (905) 855-6482

Fax:(905) 855-6373

*E-mail:*bob.gibbons@theimo.com

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the *Electricity Act, 1998*, the *Ontario Energy Board Act, 1998*, the *Market Rules* and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.

*655 Bay Street, Suite 410, P.O. Box 1, Toronto ON M5G 2K4 Canada tel 905.403.6900 toll free 1.888.448.7777 fax 905.403.6921
www.theIMO.com – helpcentre@theIMO.com*