



September 6, 2002

File: 2002-EX069

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Windsor Crawford TS – Replace 110-28.4kV Transformer T4
Notification of Approval of Connection Proposal***

CAA ID Number: 2002-EX069

The IMO has completed a review of your application to replace the failed 110-28.4kV transformer T4 at Windsor Crawford TS with a 115-28.4kV unit having identical thermal rating. Based on the information provided, we have concluded that the proposal is a like-for-like replacement of existing facilities and a formal Connection Assessment study will therefore not to be necessary.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.