

December 4, 2002

File: OP-1600

Mr. Tom Wilson
INCO Limited
18 Rink Street
Copper Cliff, Ontario
P0M 1N0

Dear Mr. Wilson:

***Notification of Approval of Connection Proposal
INCO No. 4 Substation: Reconnect and Energize Repaired Transformer T1***

CAA ID Number: 2002 – EX097

Thank you for the information on the planned return to service following its repair of the 300MVA transformer T1 at the INCO No. 4 substation and the return of the temporary relocated 150MVA transformer back to the Froid-Stobie No. 2 substation.

The original temporary connection arrangement for T1 at the INCO No. 4 substation was assessed and approved under CAA 2002 – EX028. The present proposal will return both INCO No. 4 and Froid-Stobie No. 2 substations to their original states before the failure of T1 and will not adversely impact the IMO-controlled Grid. The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments
Tel: 905-855-6482 Fax: 905-855-6129

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.