



28th February 2002

Mr Gord Haines
Ontario Power Generation Inc.
8th Floor
700 University Avenue
Toronto M5G 1X6
Ontario

Dear Mr Haines:

***Replacement of the two RSS Transformers at Lambton TGS
Notification of Approval of the Connection Proposal
CAA ID No. 2001-EX012***

Thank you for the information on the proposed replacement of the two existing Reserve Station Service (RSS) Transformers at Lambton TGS to meet the increased supply requirements that will result from the installation of the Selective Catalytic Reducers (SCRs) on generating units G3 & G4.

We have reviewed your proposal and concluded that it will have no adverse impact on the IMO-controlled grid and that a formal Connection Assessment study will therefore not to be necessary.

The IMO is therefore pleased to grant approval to complete the construction process for the replacement of the two RSS transformers.

A copy of this Notification of Approval will also be provided to the Ontario Energy Board (OEB).

Registration of the new facilities will need to be completed through the IMO's 'Facilities Registration' process before these facilities can be placed in-service.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.