

November 15, 2002

File: 2002-EX090

Mr. Carmine Marcello
Manager, Transmission System Development
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Marcello:

***Notification of Approval of Connection Proposal
Toronto Bridgman TS: Replace Existing 115kV Rod Gaps with Metal Oxide Surge Arresters
CAA ID Number: 2002-EX090***

The IMO has completed a review of your application to replace the existing 115kV rod gaps for the two 110-14.2kV step down transformers T5 and T6 and the 115kV rod gaps for the four 110-14.2-14.2kV step down transformers T11 to T14 at Toronto Bridgman TS with metal oxide gapless surge arresters. The proposal will improve the surge protection of the transformers resulting in better customer supply reliability. We have concluded that the proposal would have no adverse impact on the IMO-controlled grid and that a formal Connection Assessment would not be necessary.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments
Tel: 905-855-6482 Fax: 905-855-6129

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.