

November 12, 2002

File: 2002-EX087

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Notification of Approval of Connection Proposal
Toronto Runnymede TS – Replace Existing 115kV 600A Transformer Disconnect Switches T3-A and
T4-H***

CAA ID Number: 2002-EX087

The IMO has completed a review of your application to replace the existing 115kV 600A disconnect switches T3-A and T4-H associated with the 110-28.4kV 50/67/83MVA step-down transformers T3 and T4 at Toronto Runnymede TS with new 115kV 1,200A disconnect switches. Based on the information provided, we have concluded that the proposal is essentially a like-for-like replacement of existing facilities and that it would have no adverse impact on the IMO-controlled grid.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments
Tel: 905-855-6482
Fax: 905-855-6129

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.