

November 4, 2002

File: 2002 – EX080

Mr. Mel Yates
Manager, T&D Stations Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Notification of Approval of Connection Proposal
Wawa TS: Replace 115kV Transformer Disconnect Switch T2-K and Refurbish 230kV Breaker
Disconnect Switch AH-H***

CAA ID Number: 2002 – EX080

The IMO has completed a review of your application to replace the existing 115kV 1,200A disconnect switch T2-K associated with the 226-121kV transformer T2 with a new 115kV 2,000A disconnect switch and refurbish the 230kV breaker disconnect switch AH-H at Wawa TS. Based on the information provided, we have concluded that the proposal is essentially a like-for-like replacement of existing facilities and would have no adverse impact on the IMO-controlled grid.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.