



August 9, 2002

Mr. Gord Haines

Section Manager
Technical Compliance
Ontario Power Generation
700 University Avenue
Toronto, Ontario, M5G 1X6

Dear Mr. Haines:

***Replacement of T17 (Red Phase) at Beck2 GS
Notification of Approval of Connection Proposal
CAA ID Number: 2002-EX057***

Thank you for the detailed information that you provided on OPGI's proposal to replace the red phase single transformer on T17 at Beck2 GS. Your application indicates that the new transformer will essentially be the same as the old one and similar to those on the white and blue phases.

Based on the information provided, and in accordance with Market Manual 2, Part 2.10, Section 1.3, we have determined that the new step-up transformer at Beck2 GS represents a like-for-like replacement and a formal Connection Assessment study will not be required.

The IMO is therefore pleased to grant approval to complete this work. Copies of the Notification of Approval and the PA report will also be provided to the Ontario Energy Board (OEB).

To commence the construction process, please follow the necessary procedures and obtain the required approvals, licences and permits as may be required by the OEB, the Transmitter and other regulatory authorities.

The IMO's Facility Registration process has also been completed for this project.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons

Manager - Long Term Forecasts & Assessments

Telephone: (905) 855-6482

Fax: (905) 855-6373

E-mail: bob.gibbons@theimo.com

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the *Electricity Act, 1998*, the *Ontario Energy Board Act, 1998*, the *Market Rules* and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.

655 Bay Street, Suite 410, P.O. Box 1, Toronto ON M5G 2K4 Canada tel 905.403.6900 toll free 1.888.448.7777 fax 905.403.6921
www.theIMO.com – helpcentre@theIMO.com