



24th July 2003

Mr Mel Yates
Manager – Stations T&D Sustainment Programs
483 Bay Street, North Tower - 15th Floor
Toronto
Ontario M5G 2P5

Dear Mr Yates,

HYDRO ONE NETWORKS Inc.: Wiltshire TS
Replace the Existing Step-down Transformer T6
Notification of Approval of the Connection Proposal
CAA ID Number: 2003-EX138

Thank you for the information regarding your proposal to replace the three single-phase units that compose transformer T6 with a higher-rated, single-phase transformer.

We have reviewed your proposal and concluded that this work will have no adverse impact on the IMO-controlled grid and that a formal Connection Assessment study will therefore not be necessary.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the new facilities will need to be completed through the IMO's 'Facilities Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.