

February 11, 2003

File: 2002-EX103

Mr. Mel Yates
Manager, Stations T&D Sustainment Programs
Investment Planning Division
Hydro One Networks Inc.
483 Bay Street
15th Floor - North Tower
Toronto Ontario M5G 2P5

Dear Mr. Yates:

***Goderich TS: Replace Shunt Capacitor Breaker SC1B
Notification of Approval of Connection Proposal***

CAA ID Number: 2002-EX103

The IMO has completed a review of your application to replace the existing 38kV 1200A 14.4kA oil breaker associated with the 28.8kV 7.2MVAR shunt capacitor bank SC1 at Goderich TS with a new 48.3kV 3,000A SF₆ breaker with 31.5kA short circuit rating. As this is essentially a like-for-like replacement of existing facility, we concluded that it would have no adverse impact on the IMO-controlled grid.

The IMO is therefore pleased to grant approval to complete the proposed installation.

Registration of the proposed changes to the existing facility will need to be completed through the IMO's 'Facility Registration' process.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons
Manager – Long Term Forecasts & Assessments
Tel: 905-855-6482 Fax: 905-855-6129

cc: IMO Records

All information submitted in this process will be used by the IMO solely in support of its obligations under the Electricity Act, 1998, the Ontario Energy Board Act, 1998, the Market Rules and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.