



11th June 2004

Mr Tom Kydd
Acting Manager-Stations T&D: Sustainment Programs
Hydro One Networks Inc.
483 Bay Street, 15th Floor: North Tower
Toronto M5G 2P5
Ontario

Dear Mr Kydd:

***Manby TS: Replace the 230kV Breaker H2L23
Notification of Approval of Connection Proposal
CAA ID Number: 2004-EX198***

Thank you for the data that you provided for the 230kV SF₆ breaker that is to be installed at Manby TS to replace the bulk oil unit that recently failed.

The scheduled in-service date for the new unit is 30th June 2004.

Since the ratings for the replacement unit are similar to those of the original breaker, we have concluded that this work will have no adverse impact on the IMO-controlled grid.
[The data for the replacement breaker are attached.]

The IMO is therefore pleased to grant **conditional approval** for the replacement of the 230kV circuit breaker H2L23 at Manby TS.

Final approval will be granted upon successful completion of the IMO Facility Registration process.

Please contact facility.registration@theIMO.com if you have not received a Facility Registration Summary package within the next 10 days.

For further information, please contact the undersigned.

Yours truly,

Bob Gibbons

Manager – Long Term Forecasts & Assessments

Telephone: (905) 855-6482 Fax: (905) 855-6129 E-mail: bob.gibbons@theimo.com

cc: IMO BIRM

All information submitted in this process will be used by the IMO solely in support of its obligations under the *Electricity Act, 1998*, the *Ontario Energy Board Act, 1998*, the *Market Rules* and associated policies, standards and procedures and in accordance with its licence. All information submitted will be assigned the appropriate confidentiality level upon receipt.

655 Bay Street, Suite 410, P.O. Box 1, Toronto ON M5G 2K4 Canada tel 905.403.6900 toll free 1.888.448.7777 fax 905.403.6129
www.theIMO.com – helpcentre@theIMO.com