

# MV-90 xi Direct Lines Clarkson Station Control Centre

Revenue Metering Standing Committee  
April 2<sup>nd</sup>, 2008



- IESO used a PBX telephone system to interrogate meters
- Phone numbers in Master File had to begin with “9”
- Experienced a number of issues when communicating to meters through PBX
  - 911 calls
  - Bogus calls
- In May 2008 the decision was made to move to direct lines

- Did not achieve expected results.
- Longer interrogation times
- Could not download data from approximately 270 meters
- Had to place 6400 calls to download data from 3300 meters
- Decision was made to fail over to the BOC

Bell Switch Centre



Metering  
Installation



CSCC MV90 WS

5 km CU line

Bell Switch Centre



Metering  
Installation



T1 Line

CSCC MV90 WS



